


**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE.****Date : 22/01/2021**

It is certified that an inspection team headed by **Executive Engineer Construction Division U.P. Jal Nigam Lakhimpur Kheri** from **Construction Division U.P. Jal Nigam Lakhimpur Kheri** inspected the **Doon International Sr. Sec. School, Tehra Nighasan Road, Palia Kalan Distt Kheri. Uttar Pradesh** on **21/01/2021** and found that the **Doon International Sr. Sec. School, Tehra Nighasan Road, Palia Kalan Distt Kheri. Uttar Pradesh** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.


  
 अधिशासी अभियन्ता  
 निर्माण खण्ड उ०प्र० जल निगम  
 लखीमपुर-खीरी

Signature with Seal : \_\_\_\_\_

  
 CHAIRMAN  
 Doon International Sr. Sec. School  
 Palia (Kheri) U.P.

To,

Manager  
 Doon International Sr. Sec. School,  
 Tehra Nighasan Road, Palia Kalan  
 Distt Kheri. (262902) Uttar Pradesh  
 (Name & Address of the Institution)

  
 PRINCIPAL  
 Doon International Sr. Sec. School  
 Palia Kalan - Kheri





**DISTRICT WATER TESTING LABORATORY**  
**UTTAR PRADESH JAL NIGAM**  
**LAKHIMPUR-KHERI**

Water Testing Report


**Sampling Location** : Doon International Senior Sec. School, Palia Kalan  
**Quantity of Sample** : 1ltr.  
**Method of Sampling** : As per standard method  
**Sampling Done by** : Party  
**Date of Sampling** : 20/01/2021  
**Sample Receipt in Lab:** 21/01/2021  
**Date of Testing** : 21/01/2021  
**Sample Description** : Ground water

Sr. No.	Test	Units	Test Method	IS10500:2012 Acceptable Limit	IS10500:2012 Permissible Limit	Result
1	Colour	-	IS 3025(Part-4)	5	15	Colourless
2	Odour	-	IS 3025(Part-5)	Agreeable	Agreeable	Odourless
3	Turbidity	NTU	IS 3025(Part-10)	1	5	0.90
4	pH		IS 3025(Part-11)	6.5-8.5	No Relaxation	7.32
5	TDS	mg/l	IS 3025(Part-16)	500	2000	171.7
6	Total Alkalinity (as CaCO <sub>3</sub> )	mg/l	IS 3025(Part-23)	200	600	150
7	Fluoride (as F)	mg/l	IS 3025(Part-60)	1.0	1.5	0.189
8	Total Hardness (as CaCO <sub>3</sub> )	mg/l	IS 3025(Part-21)	200	600	195
9	Iron (as Fe)	mg/l	IS 3025(Part-53)	0.3	No Relaxation	0.130


\*BDL-Below Detection Limit

\*NT - Not Tested

**Remark:** Parameter (Turbidity, pH, TDS, Total Alkalinity, Fluoride, Total Hardness, Iron, ) tested in the laboratory are under acceptable limit.

  
**PRINCIPAL**  
Doon International Sr. Sec. School  
Palia Kalan - Kheri

  
**CHAIRMAN**  
Doon International Sr. Sec. School  
Palia (Kheri) U.P.



Lab. Chemist